

**SETPOINT™**  
MACHINERY PROTECTION SYSTEM

Minden, NV 89423 USA | www.setpointvibration.com

**Ex** ATEX: II 3 G Ex nA nC IIC 160°C(T3) Gc; ITS13ATEX47917X;  
IECEX: Ex nA nC IIC 160°C(T3) Gc; IECEX ETL 13.0041X;

**CONTROL NUMBER** 4006789

US: Class I, Zone 2, AEx nA nC IIC T4 Gc;  
Class I, Division 2, Groups A, B, C, D, T4;  
CANADA: Class I, Zone 2, Ex nA nC IIC T4 Gc;  
Class I, Division 2, Groups A, B, C, D, T4;

Intertek Input:  $V_{MIN} = 18V$ ;  $V_{MAX} = 36V$ ;  $P_{MAX} = 160W$  — — —  
See User Manual  
Operating Temp.:  $-20^{\circ}C \leq T_A \leq 65^{\circ}C$   
Relay:  $V_{MAX} = 30VDC$ ;  $I_{MAX} = 5A$

**RoHS COMPLIANT** **CE**

**EAC** CU: 2Ex nA nC IIC T3 Gc X;  
RU C-US.Г508.В.00474

**SERIAL NUMBER:**

**PART NUMBER:**  
MX2020-RCK

Label used for SETPOINT racks with Hazardous Area Approvals (MX2020/RCK where option DD=05)

**SETPOINT™**  
MACHINERY PROTECTION SYSTEM

Minden, NV 89423 USA | www.setpointvibration.com

**RoHS COMPLIANT** **CE**

**SERIAL NUMBER:**

**PART NUMBER:**  
MX2020-RCK

Label used for SETPOINT racks without Hazardous Area Approvals (MX2020/RCK where option DD=00)

**SETPOINT**

TITLE: MX2020, SETPOINT RACK, SIDE LABEL

DRAWN BY: S. SABIN	DATE: 06-29-15	
APPROVED BY: M. NELSON	DATE: 06-29-15	SHEET: 1 of 1
DWG NO: 100426-XX-AW		REV: J